

## **ATTACHMENT L**

### **Public Statement on Ultraviolet (UV) Light for Treatment of Public Water Supplies**

# **Recommended Standards For Water Works**



## **2003 Edition**

**Great Lakes – Upper Mississippi River Board of State and Provincial  
Public Health and Environmental Managers**

Illinois Indiana Iowa Michigan Minnesota Missouri  
New York Ohio Ontario Pennsylvania Wisconsin

POLICY STATEMENT  
ON  
ULTRA VIOLET LIGHT  
FOR TREATMENT OF PUBLIC WATER SUPPLIES

Ultra Violet (UV) Light treatment devices may be used to treat bacteriologically unsafe groundwater from drinking water wells. However, reviewing authorities expect water system owners to take all steps possible to obtain a naturally safe water source before considering treatment. A naturally safe water source provides the best long-term public health protection and there is no reliance on a treatment device to assure safe water. There must be a determination that the bacteriologically unsafe water is not due to the influence of surface water.

Recent research has demonstrated the effectiveness of UV as a primary disinfectant. While this policy statement does not specifically cover UV treatment for surface water or groundwater under the direct influence of surface water, it is not the intent of this policy to discourage such use. Portions of this policy are applicable to the treatment of effectively filtered surface water. The reviewing authority shall be contacted regarding use of UV treatment for these applications.

When a naturally safe groundwater source is not available, or the system owner wishes to provide UV treatment for other reasons, the following criteria shall be considered. Supplemental disinfection to provide a residual in the water distribution system may be required by the approval authority. When UV light treatment devices are used for non-health related purposes the UV device may provide doses less than indicated in the following criteria.

**A. CRITERIA FOR UV WATER TREATMENT DEVICES**

1. UV water treatment devices must comply with criteria approved by the reviewing authority or Class A criteria under ANSI/NSF Standard 55 - Ultraviolet Microbiological Water Treatment Systems; each UV water treatment device shall meet the following standards;
  - a. Ultraviolet radiation at a wavelength of 253.7 nanometers shall be applied at a minimum dose of 40 millijoules per square centimeter ( $\text{mJ}/\text{cm}^2$ ) at the failsafe set point at the end of lamp life;
  - b. The UV device shall be fitted with a light sensor to safely verify that UV light is being delivered into the reactor;
  - c. The UV light assembly shall be insulated from direct contact with the influent water by a quartz (or high silica glass with similar optical and strength characteristics) lamp jacket to maintain proper operating lamp temperature;
  - d. The design and installation of the UV reactor shall ensure that the manufacturer's maximum rated flow and pressure cannot be exceeded;
  - e. The UV assemblies shall be accessible for visual observation, cleaning and replacement of the lamp, lamp jackets and sensor window/lens;
  - f. A narrow band UV monitoring device shall be provided that is sensitive to germicidal UV light. It shall be accurately calibrated so that it indicates the true irradiance ( $\text{mJ}/\text{cm}^2$ ) at 253.7 nanometers and be installed at the location critical for that unit. The device shall trigger an audible alarm in the event the sensor or lamp fails or if insufficient dosage is detected as defined in item "a" above;
  - g. An automatic shutdown valve shall be installed in the water supply line ahead of the UV treatment system that will be activated whenever the water treatment system loses power or is tripped by a monitoring device when the dosage is below its alarm point of  $40 \text{ mJ}/\text{cm}^2$ . When power is not being supplied to the UV unit the valve shall be in a closed (fail-safe) position.
  - h. The UV housing shall be stainless steel 304 or 316L;

2. A flow or time delay mechanism wired in series with the well or service pump shall be provided to permit a sufficient time for tube warm-up per manufacturer recommendations before water flows from the unit upon startup. Where there are extended no-flow periods and fixtures are located a short distance downstream of the UV unit, consideration should be given to UV unit shutdown between operating cycles to prevent heat build-up in the water due to the UV lamp;
3. A sufficient number (required number plus one) of parallel UV treatment systems shall be provided to assure a continuous water supply when one unit is out of service;
4. No bypasses shall be installed;
5. All water from the well shall be treated. The well owner may request a variance to treat only that portion of the water supply that is used for potable purposes provided that the daily average and peak water use is determined and signs are posted at all non-potable water supply outlets.
6. The well or booster pump(s) shall have adequate pressure capability to maintain minimum water system pressure after the water treatment devices;

#### B. PRETREATMENT

The reviewing authority will determine pre and post treatment on a specific case basis depending on raw water quality. See Section G for raw water quality limitations. If coliform bacteria or other microbiological organisms are present in the untreated water, a 5 micron filter shall be provided as minimum pretreatment.

#### C. PROCESS CONTROL WATER QUALITY MONITORING

Total coliform monitoring and other parameters required by the reviewing authority will be used to evaluate UV treatment effectiveness. The minimum monitoring frequency will be as follows:

Startup and 2 weeks after start up - one raw and one treated sample.  
Monthly thereafter - raw and treated.

Monitoring for additional parameters or total coliform on an increased frequency may be required by the reviewing authority.

#### D. ONLINE MONITORING, REPLACEMENT PARTS

UV light intensity of each installed unit shall be monitored continuously. Treatment units and the water system shall automatically shutdown if the UV dosage falls below the required output of 40 mJ/cm<sup>2</sup>. Water systems that have source water exceeding 5 NTU turbidity may be required to install an online turbidimeter ahead of the UV water treatment device. An automatic shutdown valve shall be installed and operated in conjunction with the turbidimeter. Each owner shall have available on site at least one replacement lamp, a 5 micron replacement filter and, where applicable, a replacement cyst reduction filter and any other components necessary to keep the treatment system in service.

#### E. SEASONAL OPERATIONS

UV water treatment devices that are operated on a seasonal basis shall be inspected and cleaned prior to use at the start of each operating season. The UV water treatment system including the filters shall be disinfected prior to placing the water treatment system back into operation. A procedure for shutting down and starting up the UV treatment system shall be developed for or by each owner based upon manufacturer recommendations and submitted in writing to the review authority.

#### F. RECORD KEEPING AND ACCESS

A record shall be kept of the water quality test data, dates of lamp replacement and cleaning, a record of when the device was shutdown and the reason for shutdown, and the dates of prefilter replacement.

The reviewing authority shall have access to the UV water treatment system and records.

Water system owners will be required to submit operating reports and required sample results on a monthly or quarterly basis as required by the reviewing authority.

#### G. RAW WATER QUALITY CHARACTERISTICS

The water supply shall be analyzed for the following water quality parameters and the results shall be included in the UV application. Pretreatment is required for UV installations if the water quality exceeds any of the following maximum limits. When an initial sample exceeds a maximum limit, a check sample shall be taken and analyzed.

Parameter	Maximum
UV 254nm Absorption	20 percent at 1 cm
Dissolved Iron	0.3 mg/L
Dissolved Manganese	0.05 mg/L
Hardness	120 mg/L*
Hydrogen sulfide (if odor is present)	Non-Detectable
Iron Bacteria	None
pH	6.5 to 9.5
Suspended Solids	10 mg/L
Turbidity	1.0 NTU
Total Coliform	1,000/100 ML
E. Coli	**
Cryptosporidium	**
Giardia	**

\* A higher hardness may be acceptable to the reviewing authority if experience with similar water quality and reactors shows there are no treatment problems or excessive maintenance required.

\*\* These organisms may indicate that the source is either a surface water or ground water under the direct influence of surface water and may require additional filtration pretreatment. Consult the reviewing authority for guidance.

Raw water quality shall be evaluated and pretreatment equipment shall be designed to handle water quality changes. Variable turbidity caused by rainfall events is of special concern.

Adopted April, 2003